

9 Boiler 2615

8/
12/9/81
96

Cleaver Brooks

¹ AIR/² Steam ATM. M.

Model # C.B. 600-408

Date 5/27/81

SERIAL # L-70773

MAX PRESSURE - 150 PSI

INPUT 16738000 BTU/HR

Oil GPH 111.5

208 Volts 3 Ph. 60 Hz. 71 Amps.

MINIMUM CIRCUIT AMPS. 79

Blower motor 10 HP.

Air-comp motor 5 HP.

Oil Heater 7.5 KW

Oil pump motor


208 Volts 3 Ph. 60 Hz 3.5 Amp.

Oil Fired Boiler ASSEMBLY

NO. S 71805

4 D

6 Oil-



DATE OF INSPECTION
 16 July 81

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.

2. TO
 NAVFACENGCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO

15. BOILER INSPECTOR
Jesse L. Sellen
 NAVY OR NATIONAL BOARD NO.
 NAUFAC 225

BOILER DATA

3. MANUFACTURER
 ORR & SEMBOWER

4. PROPERTY NO. 9
 5. MFG. SERIAL NO. 5435005
 6. MFG. MODEL NO. 3035501

7. BUILDING NO. 2615
 8. YEAR BUILT 1954
 9. CAPACITY 12,000 #/HR

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED 151 psi
 OPERATING 100 psi
 TEST 229 psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE
 THIS UNIT WAS REPLACED WITH NEW BOILER CONTRACT NO. 79-4484. NEW UNIT WILL RETAIN PROPERTY NO. 9.

17. BOILER USE
 EXPORT

19. COMBUSTION
 _____ % CO₂ _____ % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name)
 FIRE EYE

20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 LONERGAN

22. NUMBER AND SIZE
 2-2"

23. PSI SETTING
 120-125

24. CONDITION
 —

25. MANUFACTURER
 ASHCROFT

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED


FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	ORR & SEMBOWER	
29. TYPE	GUN & NOZZLE - STEAM & AIR ATOM	
30. FUEL GRADE	#6	

31. INSPECTOR'S COMMENTS

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
R.M. Wilson
 BY DIRECTION



JIT L-70773
S.O. 98438

L-2524
MODE CB-400, 150 psi, stm.
PART NO. 524-1245

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATERTUBE
As Required by the Provisions of the ASME Code Rules

C25-1974A 6/75

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin LEBANON, PA PLANT
(Name and address of manufacturer)
2. Manufactured for BUILDING 2615, MARINE CORP BASE, CAMP LEJEUNE, NC
(Name and address of purchaser)
3. Location of Installation BUILDING 2615, MARINE CORP BASE, CAMP LEJEUNE, NC
(Name and address)
4. Type Internally Fired Boiler No. 76383 N/A 524-1245
(HRT, etc.) (Mfgr's Serial No.) (CRN) (Drawing No.)
51257 Year Built 19 81
(Nat'l. Board No.)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section I, 19 80 and Addenda to SUMMER, 1980.
(Year) (Date)

Remarks: Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report: NONE
(Name of part, item number, mfgr's name and identifying stamp)

6. Boiler Shells or Drums: No. 1 Dia. 96" Length 134" Dia. _____ Length _____

7. Shell Plates SA-515-70, 1/2"
(For each Shell or Drum state: Material Specification No. & grade, nominal thickness)

8. Longitudinal Joint(s) Welded Joint Efficiency 90%
(Seamless, Welded) (As compared to Seamless)

9. Heads NONE
(Material Specification No.; Thickness—Flat, Dished, Ellipsoidal—Radius of Dish)

10. Girth Joint(s) Welded No. of Shell Courses 2
(Seamless, Welded)

11. Tube Sheet SA-285-C, 5/8" Tube Holes 2.525"
(Mat'l Spec., Grade, Thickness) (Dia.)

12. Boiler Tubes: No. 273 SA-178-A Straight
(Mat'l. Spec., Grade) (Straight or Bent)
Dia. 2-1/2" Length 134-1/2" Gauge .105"
(If various, give max. & min.) (for thickness)

13. Furnace No. 1 Size 45" O.D. Length, each section _____ Total 134-1/4"
(O.D. or W x H)
Type Corrugated
(Plain, Adamson, Ring Reinforced, Corrugated, Combined or Stayed)

SA-285-C, .440" Seams: Type Welded
(Mat'l Spec., Grade, Thickness) (Seamless, Welded)

14. Staybolts: No. NONE Size N/A
(Diam., Mat'l. Spec. Grade Size Telltale, Net Area)

Pitch N/A Max. AWP N/A psi.
(Hor. and Vert.)

15. Stays or Braces

Location	Material Spec. No.	Type	No. & Size	Max. Pitch	Total Net Area	Fig. PFT-32 L/1	Dist. Tubes to Shell	Area to be Stayed	Max. A.W.P. psi.
(a) F.H. above tubes	SA-31-B	Diag	* 8-3/4	8-3/4	11.7816	1.09	24-1/4	905	154
(b) R.H. above tubes	SA-31-B	Diag	* 8-3/4	8-3/4	11.7816	1.09	24-1/4	905	154
(c) F.H. below tubes	N/A								
(d) R.H. below tubes	N/A								
(e) Through stays	N/A					*12 @ 1-1/4'			
(f) Dome braces	N/A								

16. Other Parts. 1. Water Column Assy. 2. Aux. Water Column Assy.
(Brief Description—i.e. Dome, Boiler Piping, etc.)

- Threaded Pipe SA-106-B 1-1/4" & 1/2" Sch. 80 M.A.W.P. 150 PSI
- Threaded Pipe SA-106-B 1" Sch. 80 M.A.W.P. 150 PSI
- Other Pressure Piping installed by Contractor
(Mat'l. Spec., Grade, Size, Material Thickness, Max. AWP)

KUNKLE
SET 150

9831
9831

Form P-2 (Back)

5
13,800 LBS PER 11

- 2 11 17. Openings: (a) Steam 1 @ 6" 300# Flg. (b) Safety Valve 2 @ 3" NPT
(No., Size, and Type)
 (c) Blowoff 2 @ 2" NPT Bottom Q (d) Feed 2 @ 2-1/2" NPT, R & L Side
(No., Size, Type, and Location) (No., Size, Type, and Location)
 (e) Manholes: No. 1 Size 11" x 15" Location Shell - Ring
 (f) Handholes: No. 6 Size 3/4" x 4 1/2" Location Shell
 No Connections to Item 17. EXCEPT AS NOTED IN ITEM 16
18. Fusible Plug (if used) N/A
(No., Diam., Location, Mfrs. Stamp)
19. Boiler Supports: No. 4 Type Legs Attachment Welded
(Saddles, Legs, Lugs) (Bolted or Welded)
20. Max. AWP 150 psi Based On PG-27 Heating Surface 2000 sq ft
(Code Par. and/or Formula) (Total)
21. Shop Hydrostatic Test 225 psig. N/A kw.
(Electric Boilers)

CERTIFICATE OF COMPLIANCE

We certify the statements in this data report to be correct. Cleaver-Brooks Division
 Date May 8, 1981 Signed John D. Freed of Aqua-Chem, Inc.
(Manufacturer) (Authorized Representative)
 Our Certificate of Authorization No. 10905 to use the (A) or (S) S Symbol expires
January 15, 1983

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division of Aqua-Chem, Inc. at Lebanon, Pa.
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or
 Province of Pennsylvania and employed by The Hartford Steam Boiler I & I Co.
 of Hartford, Conn. have inspected parts of this boiler referred to as data items
1-8, 10-13, 15, 17-21 and have examined Manufacturer's Partial Data Reports for items
NONE
 and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable
 sections of the ASME BOILER AND PRESSURE VESSEL CODE.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler
 described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any
 personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date May 8, 1981 Commissions NB 5004 PA 1743
Walter A. Jopak Nat'l Board, State, Province and No.
 WALTER A. JOPAK

CERTIFICATE OF COMPLIANCE

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND
 PRESSURE VESSEL CODE.
 Date _____ Signed _____ By _____
(Assembler) (Representative)
 Our Certificate of Authorization No. _____ to use the (A) or (S) _____ Symbol expires
 _____ 19 _____

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or
 Province of _____ and employed by _____ of _____
 have compared the statements in this Manufacturer's Data Report with the described boiler and state that the parts referred to as data
 items _____, not included in the certificate of shop inspection, have been
 inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled
 this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was
 inspected and subjected to a hydrostatic test of _____ psi.
 By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler
 described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any
 personal injury or property damage or a loss of any kind arising from or connected with this inspection.
 Date _____ Commissions _____
 _____ Nat'l Board, State, Province and No.
 Inspector

DATE OF INSPECTION
 21 MAY 1979

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT OFFICER CAMP LETJEUNE N.C.
 2. TO
 NAVFACENG COM NORFOLK VA.

14. CERTIFICATE ISSUED YES NO
 EXPIRES 16 NOV 1979
 15. BOILER INSPECTOR
 Jesse L. Sellen
 NAVFAC 225

BOILER DATA

3. MANUFACTURER
 ORR & SEMBOWER

4. PROPERTY NO. 9	5. MFG. SERIAL NO. 5435205	6. MFG. MODEL NO. 3035501
7. BUILDING NO. 2615	8. YEAR BUILT 1954	9. CAPACITY 12,000 #/HR
10. FUEL (Check) <input type="checkbox"/> COAL <input checked="" type="checkbox"/> OIL <input type="checkbox"/> GAS		11. PRESSURE DESIGNED 151 psi OPERATING 100 psi TEST 227 psi
12. FEED WATER TREATMENT <input checked="" type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY		13. TYPE <input type="checkbox"/> WATER TUBE <input checked="" type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
 EXPORT
 18. COMBUSTION CONTROL (Mfg. Name)
 FIREYE
 19. COMBUSTION
 % CO₂ _____ % EXCESS O₂ _____
 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 LONERGAN
 22. NUMBER AND SIZE
 2-2"
 23. PSI SETTING
 120-125
 24. CONDITION
 —

STEAM PRESSURE GAUGE

25. MANUFACTURER
 ASHCROFT
 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED


FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER	ORR & SEMBOWER	NONE
29. TYPE	GUN & NOZZLE - STEAM & AIR ATOM	
30. FUEL GRADE	#6	

31. INSPECTOR'S COMMENTS
 HYDROSTATIC TEST REVEALED TWO TUBE WEARS AT SEAL WELDS ON 1ST PASS TUBE ENDS. THESE LEAKS WERE REPAIRED AND BOILER WAS RETESTED SATISFACTORILY.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 F.E. Cone
 BY DIRECTION



DATE: 21 May 1979

ACTIVITY: Marine Corps Base, Camp Lejeune, North Carolina

BUILDING NO: 2615 BOILER NO: 9

Based on the existing condition and present rate of deterioration, it is estimated that the boiler has a remaining life of

5 or more years

~~25~~ ^{2.5} years

The following corrective action is recommended:

1. This boiler has been in service over 25 years.
 2. The oil burner should be replaced due to age and unavailability of replacement parts. Combustion efficiency for 1977 and 1978 was less than 80 percent.
 3. Tube ends on first pass were seal welded in 1978 and hydrostatic tested satisfactorily at 227 PSI.
 4. Hydrostatic test this date revealed two tube weeps at seal welds. These leaks were repaired and boiler was retested satisfactorily.
 5. Based on this information and the past history of a same type boiler, No. 54 located in Building BB-9, the remaining life of this boiler is estimated to be from two to five years.
- _____
- _____
- _____
- _____
- _____
- _____

